



High Performance Buildings and Occupant Comfort

Peter Simmonds, Ph.D., FASHRAE, FIBPSA, FFTI
B and S Analytics, Marina Del Rey and Hong Kong
peter@petersimmonds.com

This ASHRAE Distinguished Lecturer is brought to you by the
Society Chapter Technology Transfer Committee



ASHRAE is a Registered Provider with The American Institute of Architects Continuing Education Systems. Credit earned on completion of this program will be reported to CES Records for AIA members. Certificates of Completion for non-AIA members are available on request.

This program is registered with the AIA/CES for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product. Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.





**EDUCATION
PARTNER**

High Performance Buildings and Occupant Comfort

By Peter Simmonds

GBCI cannot guarantee that course sessions will be delivered to you as submitted to GBCI. However, any course found to be in violation of the standards of the program, or otherwise contrary to the mission of GBCI, shall be removed. Your course evaluations will help us uphold these standards.

Course ID: 0090010881

Approved for:

X

General CE hours



X

LEED-specific hours



Learning Objectives for this Session

- PPD/PMV analysis can be used for space comfort diagnostics.
- Using comfort analysis provides more information for the design team.
- Not all analysis tools are capable of simulating occupant comfort.
- Multiple use spaces still require to provide occupant comfort.
- To understand the limitations of maintaining comfort
- To understand the possible energy consumption.

ASHRAE is a Registered Provider with The American Institute of Architects Continuing Education Systems. Credit earned on completion of this program will be reported to ASHRAE Records for AIA members. Certificates of Completion for non-AIA members are available on request.

This program is registered with the AIA/ASHRAE for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product. Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.

The Game

- } How do we get to net zero?
- } How do we provide occupant comfort?



25 years ago

CH-93-10-4

THERMAL COMFORT AND OPTIMAL ENERGY USE

P. Simmonds
Member ASHRAE


25 years ago



ASHRAE 90.1, 2013 Appendix G, Exceptions:

} Setpoints and schedules for HVAC systems that automatically provide occupant thermal comfort via means other than directly controlling the air dry-bulb and wet-bulb temperature may be allowed to differ, provided that equivalent levels of occupant thermal comfort are demonstrated via the methodology in Section 5.2.3 of ASHRAE Standard 55, "Elevated Air Speed," or Appendix D of Standard 55, "Computer Program for Calculation of PMV-PPD."

Thermal Comfort Standard




Thermal Comfort Definitions

Predicted Mean Vote (PMV):


an index that predicts the mean value of the votes of a large group of persons on the seven-point thermal sensation scale.

Predicted Percentage of Dissatisfied (PPD):

an index that establishes a quantitative prediction of the percentage of thermally dissatisfied people determined from PMV.



THERMAL COMFORT



- 1) Metabolic rate.
- 2) Clothing insulation.
- 3) Air temperature.
- 4) Radiant temperature
- 5) Air speed.
- 6) Humidity



Early work



The Groninger Museum, Groningen, the Netherlands



Akron Art Museum



Akron Art Museum



The original building




Pearl River, China







Thermal Comfort – GZDI Design



Thermal Comfort

Percentage of People Dissatisfied in July at 12:00 hours
Minimum: 5.27 % - Maximum: 8.41 %
Room typical floor (Analysis Plane at z = 0.00 m)



Real Time Comfort Control



8 Canada Square, London



Typical Trading Floor



Past Experience

- } No scientific approach to complaints
- } Complaints received regarding draughts, 'too hot' , 'too cold'
- } Reactive activity based on individual experience / 'knee jerk reaction'
- } Average quantity of daily calls / emails received across all three floors were 3 per day
- } Only factor that was measured that influenced thermal comfort was Air Temperature
- } Controls / unit failures that were not identified




Recent Complaints

PPD = 5-7%


Complaints

Air Velocities




Profile shows complaints post Christmas Change activity


PPD/PMV Real Time Control



PPD Thermal Comfort Index



PPD at Room design of 22 °C



PPD at Room design of 24 °C

Reference: PPD Thermal Comfort Toolkit
<http://smap.cbe.berkeley.edu/comforttool>

Current Experience


- } Installed Predicted Percentage of Dissatisfied (PPD) system
- } Now measure the 6 factors that influence thermal comfort – Air Temperature, Relative Humidity, Air Velocity, Radiant Temperature, Clothing, Metabolic Rate
- } Average daily complaints now reduced to around 1 per day
- } Smaller zones giving more accurate control
- } Thermal comfort conditions are logged



Cooper Union



The efficiency of the façade-midseason





The Living Skin



Cooper Union


SL-08-053

Modeling the Heat Gain of a Window with an Interior Shade— How Much Energy Really Gets In?


Douglas C. Hittle, PhD
Fellow ASHRAE

Peter Simmonds, PhD
Fellow ASHRAE

Cooper Union




Cooper Union



Cooper Union- Results

- } The resulting utility costs are \$400,770 compared to \$602,672 for the budget case.
- } The total energy cost savings is 34% and is therefore eligible for 7 LEED points.
- } The proposed case is predicted at consuming 1,170,365 kWh of electricity per year and the budget case is predicted at consuming 2,184,932 kWh of electricity per year.
- } This is a 46% reduction below the budget case.


Space Control System







Harbin Bank, Beijing



The Climate Facade






Winter


Summer

Analysis Plane




Summer Comparison

Percentage People Dissatisfied -Summer




Winter Comparison

Percentage People Dissatisfied - Winter





CO2 Emissions




Louis Vuitton Museum, Paris



LVMH- Paris



The Forum




Forum Conditioning system

Variable volume displacement ventilation system


Radiant ceiling for heating and cooling

Exhaust air


Radiant floor for heating and cooling




The Forum





CFD for Comfort analysis



CFD for Comfort analysis



CFD for Comfort analysis



Claremont McKenna College



Typical Office



Meeting room



Claremont McKenna College

Energy consumption 48% lower than code required building.




Terminal 2 – 680,000m²






Breathing Skin Concept




Radiation Exchange Concept

Material and Construction




the inside surface should have a low-e coating to reflect the cool radiation from the floor back into the space



Radiant floor and displacement ventilation


Radiant Floor & Displacement Ventilation

- A vertical closed-loop ground heat exchanger is used for radiant floor heating and cooling systems.
- A displacement ventilation system is connected to a cool tube system installed in an underground pathway.
- The radiant floor systems and the displacement ventilation system are designed to maintain a constant level of thermal comfort in the occupied zone.




Roof Performance- Summer

Temperatures of Roof - Summer




Occupant Comfort - Summer




Roof Performance- Winter

Temperatures of Roof - Winter



Occupant Comfort - Winter



Two Tabor Tower, Denver



Two Tabor Tower, Denver



- } The new 30 to 33-story Two Tabor Center has been designed with a focus on providing tenants a productive and healthy work environment that is employee-centric and provides easy access to the many amenities of Tabor Center and the 16th Street Mall.
- } Two Tabor Center will add approximately 637,000 to 692,000 rentable square feet of class AA office space to Tabor Center, creating one of the largest office complexes in Denver with over 1,217,000 rentable square feet of office space. Retail space occupies the ground level of Two Tabor Center along 17 St. and Larimer Street. Entrances to a 1,700-space underground parking garage.


Comparison of glass types

| | Cavity | floor area | Solar Radiation (btu/h) | Transmission (btu/h) | total | Envelope load per SF floor area (Btuh/sf) |
|-------------------|----------------------|------------|-------------------------|----------------------|-----------|---|
| VUE1-30 (40%) | Air(10%)/Argon (90%) | 765,272 | 1,133,853 | 629,567 | 1,763,420 | 2.30 |
| VNE4-53 (40%) | Air(10%)/Argon (90%) | 765,272 | 1,496,149 | 623,118 | 2,119,268 | 2.77 |
| VRE1-38 (40%) | Air(10%)/Argon (90%) | 765,272 | 1,516,277 | 648,914 | 2,165,191 | 2.83 |
| VP1-13 (40%) | Air(10%)/Argon (90%) | 765,272 | 1,328,420 | 1,059,492 | 2,387,911 | 3.12 |
| VNE1-63 (40%) | Air(10%)/Argon (90%) | 765,272 | 1,905,410 | 640,315 | 2,545,725 | 3.33 |
| VUE1-30 (65%) | Air(10%)/Argon (90%) | 765,272 | 1,842,511 | 824,042 | 2,666,553 | 3.48 |
| VNE1-53 (65%) | Air(10%)/Argon (90%) | 765,272 | 2,431,243 | 788,959 | 3,220,201 | 4.21 |
| VNE4-53 (65%) | Air(10%)/Argon (90%) | 765,272 | 2,431,243 | 813,563 | 3,244,805 | 4.24 |
| VRE1-38 (65%) | Air(10%)/Argon (90%) | 765,272 | 2,463,950 | 855,480 | 3,319,430 | 4.34 |
| VP1-13 (65%) | Air(10%)/Argon (90%) | 765,272 | 2,158,682 | 1,522,669 | 3,681,351 | 4.81 |
| ASHRAE 90.1 (40%) | Air(10%)/Argon (90%) | 765,272 | 2,683,676 | 1,093,886 | 3,777,561 | 4.94 |
| VNE1-63 (65%) | Air(10%)/Argon (90%) | 765,272 | 3,096,291 | 841,508 | 3,937,799 | 5.15 |
| ASHRAE 90.1 (65%) | | 765,272 | 4,360,973 | 1,578,560 | 5,939,533 | 7.76 |
| VNE1-53 Air (65%) | Air (100%) | 765,272 | 2,507,560 | 995,206 | 3,502,765 | 4.58 |





o
p
y
r
i
g
h
t
B
u
i
l
d
i
n
g
a
n


External Load (btu/h)



90.1 40% glass




90.1 65% glass





o
p
y
r
i
g
h
t
B
u
i
l
d
i
n
g
a
n


EUI (kBtu/ft2)







o
p
y
r
i
g
h
t
B
u
i
l
d
i
n
g
a
n

Summer 65% glazing Net Zero






Comparison of Building Loads – Design Results



Wilshire/Gayley Residential



Acceptable Operative Temperature (to) Ranges for Naturally Conditioned Spaces



Exponentially weighted running mean temperature

$$T_{rm} = (1-a) \cdot \{T_{od-1} + a \cdot T_{od-2} + a^2 T_{od-3} \dots\}$$

$$T_{rm}^n = (1-a) \cdot T_{od}^{n-1} + a \cdot T_{rm}^{n-1}$$

a is a constant ($a < 1$),

T_{rm} Running mean temperature


T_{rm}^n is T_{rm} on day n

In this database $T_{rm}^X = T_{rm}$ for $a = X/100$


T_{od} Daily mean temperature



ASHRAE 55 Adaptive Comfort Comparison of Indoor Operative Temperature to Flat Mean and Prevailing Mean Criteria: Wilshire-Gayley, November, alpha = 0.7 for prevailing mean



comparison of maximum air velocities



- average air speed without occupant control Calculated
- Graphic comfort zone 40 fpm
- Adaptive comfort no air speed 59 fpm
- Adaptive comfort with air speed 236 fpm




comparison of maximum air velocities

- } For operative temperatures (t_o) above 25.5°C (77.9°F), the upper limit to average air speed (V_a) should be 0.8 m/s (160 fpm).
- } For operative temperatures (t_o) below 22.5°C (72.5°F), the limit to average air speed (V_a) should be 0.15 m/s (30 fpm).
- } For operative temperatures (t_o) between 22.5°C and 25.5°C (72.5°F and 77.9°F), the upper limit to average air speed (V_a) it is acceptable to approximate the curve in I-P and SI units by the following equation:
 - } $V_a = 50.49 - 4.4047 t_o + 0.096425(t_o)^2$ (m/s, °C)
 - } $V_a = 31375.7 - 857.295 t_o + 5.86288(t_o)^2$ (fpm, °F)




GuoXing Avenue Mixed Use
Haikou, Hainan, China


% shading through fins




Glazing: climate facade Angle of incidence (°): 45



Comparison of EUI (kWh/m²)



CO2 Emissions




O'Hare Airport Expansion



O'Hare Airport Expansion




O'Hare Airport Expansion



O'Hare Airport Expansion




Stratified Conditions for 22nd JULY




Energy Use Intensity (EUI) kBtu/h.ft²



PPD for a summers day in the Concourse



PPD for 1st to the 31st JULY - Concourse



1766-RP

Development of a Unified Tool for Analysis of Room Loads and Conditions

Principal Investigators:
Chip Barnaby
Peter Simmonds

January 27, 2017
Las Vegas


Goal

To integrate software previously developed by several ASHRAE research projects to create a single application that includes all of the necessary algorithms for calculating space heat balance and radiant energy exchange.

This application is provisionally named RPEHB and will be created by combining RPE (from 1383-RP) and the heat balance room model (originating in 987-RP and enhanced by 1199-RP and 1311-RP).

The Process in Practice

SketchUp




SketchUp takes the geometry and converts this into a building model that can be read by OpenStudio

OpenStudio



OpenStudio builds the simulation model with constructions, schedules, design weather, ...


RPEHB




Visualization of simulation results that evaluate space conditions with and without radiant systems



SketchUp



OpenStudio - constructions



OpenStudio – room loads

Sat 2 June 4 2016 1:00pm
File Preferences Components & Measures Help

Room Types

Drop Search Type
General Loads Measure Tags Custom

Filter: Load Type
Show all loads

| Space Type Name | Load Name | Multipier | Definition | Schedule | Activity Schedule (People Only) |
|---------------------------------|---------------------------|-----------|-------------------------------------|-------------------------|---------------------------------|
| 09 - Office - BreakRoom - C21-3 | BreakRoom - C21-3 People | 1.000000 | BreakRoom - C21-3 People Definition | Office Mac Occ | Office Activity |
| | BreakRoom - C21-3 Lights | 1.000000 | BreakRoom - C21-3 Lights Definition | Office Bldg Light | |
| | C21-3 Electric Equipment | 1.000000 | 1-3 Electric Equipment Definition | Office Bldg Equip | |
| | Room - C21-3 Infiltration | | | Office Infil Quarter On | |
| 09 - Office - BreakRoom - C24-8 | BreakRoom - C24-8 People | 1.000000 | BreakRoom - C24-8 People Definition | Office Mac Occ | Office Activity |
| | BreakRoom - C24-8 Lights | 1.000000 | BreakRoom - C24-8 Lights Definition | Office Bldg Light | |
| | C24-8 Electric Equipment | 1.000000 | 4-8 Electric Equipment Definition | Office Bldg Equip | |
| | Room - C24-8 Infiltration | | | Office Infil Quarter On | |
| | SeedOffice - C21-3 People | 1.000000 | Office - C21-3 People Definition | Office Work Occ | Office Activity |


My Model Library Edit

- Default Construction Sets
- Default Schedule Sets
- Design Specification Outdoor Air
- People Definitions
- Lights Definitions
- Luminaire Definitions
- Electric Equipment Definitions
- Gas Equipment Definitions
- Water Use Equipment Definitions
- Hot Water Equipment Definitions
- Steam Equipment Definitions
- Other Equipment Definitions
- Internal Mass Definitions


Start

6:18 PM 6/2/2016

RPEHB – Import and Display



Explore Results ...



MRT

PHOENIX - in.rtd

Options Help

Display

MRT Normals

Height (m) 0.6

Spacing (m) 0.5

Z apply Occlusions

Scale

32.00 °C
32.00
31.80
31.60
31.40
31.20
31.00
30.80
30.60
30.40
29.80
29.20
28.80
28.00

Lock

Room Conditions

| | Heating | Cooling |
|-------------------|---|---------|
| T setpoint (°C) | 20.0 | 24.0 |
| T supply (°C) | 50.0 | 13.0 |
| T air (°C) | 24.0 | |
| System output (W) | Air: 48106 6168 l/s @ 13 °C Panel: 0 Total: 48106 | |

uWhole-room results

MRT (°C) 26.5 TOP (°C) 26.2

PMV 0.05

PPD (%) 5

Neutral

Job

Building 1
SEVING
lat=29.80° N long=116.47° E

Outdoor conditions

BEIJING Avy Clj 4S Condra DB->MVA

Rooms CFA: 9295 m² Panel: 0.0 m²

Thermal Zone 1

Date/time Jul 21 16:03 ☑ Solar

Tout: 34.0 °C - Ek: 737 - Ed: 182 - Wsrf

Surfaces

| Surface | Exr temp (°C) | Surf temp (°C) | Flux | Conv | Rrad | Total |
|----------------|---------------|----------------|------|------|------|-------|
| Surface 1 | | | | | | |
| Surface 2 | | | | | | |
| Surface 3 | | | | | | |
| Sub-Surface 10 | | | | | | |
| Sub-Surface 11 | | | | | | |
| Sub-Surface 4 | | | | | | |
| Sub-Surface 5 | | | | | | |
| Sub-Surface 6 | | | | | | |
| Sub-Surface 7 | | | | | | |
| Sub-Surface 8 | | | | | | |
| Sub-Surface 9 | | | | | | |
| Surface 8 | | | | | | |

Control Parameters

☑ Seated Standing

Activity (met) 1.0

Clothing (clo) 0.50

Relative humidity (%) 53

Air velocity (m/s) 0.10

Direct sun in comfort

Can Current Zone Selections Provide Occupant Comfort?

BY PETER SIMMONDS, FELLOW ASHRAE; TOM HARTMAN, LIFE MEMBER ASHRAE

For HVAC system design, office buildings are typically divided into local thermal zones made up of multiple occupied spaces (*Figure 1*). Thermal zones are areas of the occupied building selected by the designer in which it is believed uniform thermal conditions can be maintained throughout with the means of local thermal distribution and control employed. The number and size of zones are based on several criteria, but designers typically employ rules of thumb in selecting and laying out thermal zones.

In an office building with similar internal loads throughout, such rules usually require a minimum of one zone for each of the perimeter exposures on each floor, a maximum number of separate spaces

ceiling or radiant floor that is individually controlled for that area."

Determining whether a zone configuration can achieve acceptable comfort for its occupants requires



Thank you

Building and Systems Analytics LLC
4209 Via Marina, #408
Marina Del Rey, CA 90292, USA
Unit 1202, 12/F, Malaysia Building
50 Gloucester Road
Wanchai, Hong Kong

www.petersimmonds.com
peter@petersimmonds.com