



INTERIOR LIGHTING FIXTURE SCHEDULE					
TYPE	DESCRIPTION	LAMPS	VOLTAGE	MANUFACTURER AND MODEL NO.	COMMENTS
'A' NOT USED	2' x 2' SURFACE MOUNTED LED PANEL	31.4w LED 3500K	MVOLT	ELITE #22-FPL-BL-LED-3000L-DIM10-MVOLT-35K-85 W/ 22-FPL1-LED-SMK	0-10V DIMMING DRIVER, ALUMINUM FRAME AND SATIN WHITE LENS
'A2' NOT USED	2' x 2' SUSPENDED LED PANEL	31.4w LED 3500K	MVOLT	ELITE #22-FPL-BL-LED-3000L-DIM10-MVOLT-35K-85 W/ 22-FPL1-LED-SMK-GSS	0-10V DIMMING DRIVER, ALUMINUM FRAME AND SATIN WHITE LENS, WITH SUSPENSION KIT
'B' NOT USED	2' x 4' SURFACE MOUNTED LED PANEL	38.8w LED 3500K	MVOLT	ELITE #24-FPL-BL-LED-3000L-DIM10-MVOLT-35K-85	0-10V DIMMING DRIVER, ALUMINUM FRAME AND SATIN WHITE LENS
'BX' NOT USED	2' x 4' SURFACE MOUNTED LED PANEL	45.8w LED 3500K	MVOLT	ELITE #24-FPL-BL-LED-3000L-DIM10-MVOLT-35K-85 -O-EMG-LED-10W	SIMILAR TO TYPE 'B1' EXCEPT PROVIDED WITH A MINIMUM 90 MINUTE EMERGENCY BATTERY BACK-UP
'C'	8'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE	40w LED 3000K	120V	ALW #RLP1S-S8-LOW/80/3000/0-10V/S-EXT-SB-UNV	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'C-X'	8'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE WITH REMOTE EMERGENCY BATTERY BACKUP	47w LED 3000K	120V	ALW #RLP1S-S8-LOW/3000/0-10V/S-EXT-SB-UNV-EMB/1	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'C-2' NOT USED	10'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE	50w LED 3000K	120V	ALW #RLP1S-S10-LOW/80/3000/0-10V/S-EXT-SB-UNV	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'C-2X' NOT USED	10'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE WITH REMOTE EMERGENCY BATTERY BACKUP	62w LED 3000K	120V	ALW #RLP1S-S10-LOW/3000/0-10V/S-EXT-SB-UNV-EMB/1	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'C-3'	12'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE	60w LED 3000K	120V	ALW #RLP1S-S12-LOW/80/3000/0-10V/S-EXT-SB-UNV	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'C-3X'	12'-0" LONG PENDANT MOUNTED LINEAR LED FIXTURE WITH REMOTE EMERGENCY BATTERY BACKUP	72w LED 3000K	120V	ALW #RLP1S-S12-LOW/3000/0-10V/S-EXT-SB-UNV-EMB/1	ELV DIMMING DRIVER, EXTRUDED ALUMINUM HOUSING WITH SATIN BLACK FINISH, DIFFUSED WHITE LENS
'D' NOT USED	PIPELINE WALL VANITY 6' LED FIXTURE	5W/FT LED 3000K	120V	ALW #RLP2C-S6-LOW/80/3000/0-10V/S-LENS-SB-UNV	DIMMING DRIVER, BRUSHED ALUMINUM CONSTRUCTION WITH EXTRUDED ACRYLIC DIFFUSER
'F'	4'-0" LONG CHAIN HUNG LED STRIP FIXTURE	47w LED 3500K	120V	ELITE #4-OEC-LED-3000L/4000L/5000L-DIM10-MVOLT-35K-85-O-EMG-LED-10W-OCGSS	0-10V DIMMING DRIVER, COLD ROLLED STEEL CHANNEL WITH BAKED WHITE ENAMEL FINISH AND FROSTED ACRYLIC SNAP ON/SNAP OFF LENS
'F-X'	4'-0" LONG CHAIN HUNG LED STRIP FIXTURE	54w LED 3500K	120V	ELITE #4-OEC-LED-3000L/4000L/5000L-DIM10-MVOLT-35K-85-O-EMG-LED-10W-OCGSS	SIMILAR TO TYPE 'F' EXCEPT PROVIDED WITH A BATTERY BACK-UP
'G'	4'-0" LONG SURFACE MOUNTED LED STRIP FIXTURE	47w LED 3500K	120V	ELITE #4-OEC-LED-3000L/4000L/5000L-DIM10-MVOLT-35K-85	0-10V DIMMING DRIVER, COLD ROLLED STEEL CHANNEL WITH BAKED WHITE ENAMEL FINISH AND FROSTED ACRYLIC SNAP ON/SNAP OFF LENS
'GX' NOT USED	4'-0" LONG SURFACE MOUNTED LED STRIP FIXTURE	54w LED 3500K	120V	ELITE #4-OEC-LED-3000L/4000L/5000L-DIM10-MVOLT-35K-85O-EMG-LED-10W	SIMILAR TO TYPE 'G' EXCEPT PROVIDED WITH A BATTERY BACK-UP
'H'	12" DIAMETER GLASS GLOBE PENDANT MOUNTED LED FIXTURE	14w LED 3000K	120V	CBMC #ORN-141P-MB W/LED11WA19/OMN/830-DIM-B	1 X 14W LED031 PRO-T38LED (INCLUDED), BLACK FINISH, TRIAC DIMMING
'J' NOT USED	8" ASYMMETRIC WALL WASHER	9W/FT LED 3000K	120V	ALW #CMLS-S8-MED/80/3000/0-10V/S-LENS-TB-UNV-COMBO	0-10V DIMMING, TEXTURED BLACK FINISH, FIXTURE TO BE MOUNTED AT 8'-6" AFF.
'J-2'	6" ASYMMETRIC WALL WASHER	9W/FT LED 3000K	120V	ALW #CMLS-S8-MED/80/3000/0-10V/S-LENS-TB-UNV-COMBO	0-10V DIMMING, TEXTURED BLACK FINISH, FIXTURE TO BE MOUNTED AT 8'-6" AFF.
'RC-1' NOT USED	6" CYLINDER RECESSED CAN LIGHT	12w LED 3000K	120V	NORA LIGHTING #NYLS2-C15130FBB6AC	0-10V DIMMING DRIVER, ALUMINUM HOUSING WITH MATTE BLACK FINISH AND FROSTED GLASS LENS
'L-2' NOT USED	6" DIAMETER RIGID PENDANT MOUNTED FIXTURE	15.5w LED 3000K	120V	NORA LIGHTING #NYLS1-8C15130FBB6AC	0-10V DIMMING DRIVER, ALUMINUM HOUSING WITH MATTE BLACK FINISH AND FROSTED GLASS LENS
'L-3' NOT USED	6" DIAMETER DIRECTIONAL PENDANT FIXTURE	20w LED 3000K	120V	BRUCK #350441-20LM-30K-90-60-120-ELV-BK-SMBK	TO BE DETERMINED BY LIGHTING VENDOR AND OWNER
'M' NOT USED	FLEXFIRE ULTRABRIGHT ARCH. DYNAMIC TUNABLE WHITE SERIES LED STRIP LIGHT	4.4W/FT LED 3000K	120V	CORE #LSM105MX-22K-60K-PF-24V	0-10V DIMMING DRIVER, COVE LIGHTING
'XA' NOT USED	WALL MOUNTED, COMBINATION EXIT SIGN/EMERGENCY LIGHTING UNIT (2 LAMP HEADS)	(2) 1.5W LED	120/277V	BEST #CEU-3-G-2	THERMOPLASTIC HOUSING WITH WHITE FINISH AND GREEN LETTERS, HIGH OUTPUT BATTERY BACK-UP
'XB'	UNIVERSAL MOUNT EXIT SIGN FACES AND ARROWS AS INDICATED ON PLAN	1W LED	120/277V	BEST #EZRXTU2GWEM	THERMOPLASTIC HOUSING WITH WHITE FINISH AND GREEN LETTERS, HIGH OUTPUT BATTERY BACK-UP
'S-2' NOT USED	EXTERIOR WALL PACK FIXTURE	45w LED	120V	WESTGATE #CDLX-MD-15-45W-40K	
'S-3' NOT USED	EXTERIOR WALL PACK FIXTURE WITH BATTERY BACK-UP	60w LED 4000K	120V	LSI INDUSTRIES #WPSLL-6L-UNV-40-PC120-CWBB-BZA	

LIGHTING FIXTURE NOTES:

- ALTERNATE LIGHTING MANUFACTURER'S EQUIPMENT BY COOPER, PHILIPS OR HUBBELL, SHALL BE SIMILAR IN PERFORMANCE, PHYSICAL APPEARANCE AND CONSTRUCTION TO BE CONSIDERED AS EQUAL TO UNITS SPECIFIED.
- ALTERNATE LIGHTING FIXTURE TYPES PROPOSED TO BE SUBSTITUTED BY BIDDING CONTRACTOR MUST BE PRE-APPROVED DURING BIDDING. CONTRACTOR, OR LIGHTING REPRESENTATIVE SHALL FAX OR EMAIL ALL SUCH REQUESTS WITH FIXTURE CUTS TO ENGINEER AT LEAST ONE WEEK PRIOR TO SUBMITTING BIDS. ENGINEER SHALL REVIEW THE PROPOSED ALTERNATE LIGHTING FIXTURES AND ISSUE A WRITTEN ACCEPTANCE OR DENIAL BY RETURN FAX OR EMAIL. VERBAL APPROVAL WILL NOT BE ACCEPTABLE.
- ALL SHOP DRAWINGS SUBMITTED AFTER AWARD OF CONTRACTOR FOR LIGHTING FIXTURES WHICH WERE NOT PRE-APPROVED WILL BE REJECTED.
- CHAIN HUNG TYPE 'F' FIXTURES WITH TOP OF FIXTURE FLUSH WITH BOTTOM OF STRUCTURAL STEEL.
- TYPE 'H' FIXTURES SHALL BE MOUNTED WITH BOTTOM AT 7'-0" AFF.
- TYPE 'J' FIXTURES SHALL BE SURFACE MOUNTED TO BOTTOM OF STRUCTURAL STEEL.
- TYPE 'L' FIXTURES SHALL BE PENDANT MOUNTED WITH BOTTOM OF FIXTURE FLUSH WITH BOTTOM OF STRUCTURAL STEEL.



TYPICAL OCCUPANCY SENSOR/WALL SWITCH WIRING DETAIL
N.T.S.



DAMIAN FARRELL DESIGN GROUP

359 METTY DRIVE, SUITE 4A
ANN ARBOR, MI 48103
tel: 734.998.1331



01.12.2024

FOR PERMIT ISSUE

C3 - BRANSON MO
3125 GREEN MOUNTAIN DRIVE
BRANSON, MO 65616

DATE	DESCRIPTION
12.28.2023	REVIEW SET
01.12.2024	PERMIT SET

CHECKED	DJQ/PJF
DRAWN	BJK
HEI PROJECT NO.	R23-4590.006

LIGHT FIXTURE SCHEDULE, NOTES & DETAILS

E4.0

