



DAMIAN FARRELL DESIGN GROUP

359 METTY DRIVE, SUITE 4A
ANN ARBOR, MI 48103
tel: 734.998.1331



01.12.2024

FOR PERMIT ISSUE

C3 - BRANSON MO
3125 GREEN MOUNTAIN DRIVE
BRANSON, MO 65616

DATE: 12.28.2023
01.12.2024

DESCRIPTION: REVIEW SET
PERMIT SET

CHECKED: DJQ/PJF
DRAWN: BJK
HEI PROJECT NO.: R23-4590.006

ELEC. ONE-LINE DIAGRAM & PANEL SCHEDULES

E3.0



HALLBERG ENGINEERING
Mechanical/Electrical Consulting Engineers
1750 Commerce Court
White Bear Lake, MN 55110
Phone (651) 748-1100 • Fax (651) 748-3370

EXISTING PANEL 'M-A'												
Location: Mezzanine		AIC: EXISTING										208/120 Volt, 3ø, 4w
Mounting: Surface												Main: MCB 400A
Circuit Description	KVA	CB	NO.	NOTE	A	B	C	NOTE	NO.	CB	KVA	Circuit Description
WATER HEATER (XEWH-1)	3.7		1		X				2	50/2	2.8	CU-1
	3.7	40/3	3	C		X			4		2.8	
	3.7		5				X		6	30/2	1.7	CU-2
	3.7		7		X				8		1.7	
WATER HEATER (XEWH-2)	3.7	40/3	9	C		X			10	50/2	2.8	CU-3
	3.7		11				X		12		2.8	
FCU-1/HP-1	0.8	20/2	13	B	X				14	50/2	2.8	CU-4
	0.8		15			X			16		2.8	
SPARE			17				X		18	20/1		SPARE
SPACE			19		X				20			
SPACE			21			X			22	30/3		SPARE
SPACE			23				X		24			
SPACE			25		X				26		2.3	
SPACE			27			X			28	40/3	2.3	XCU-5
SPACE			29				X		30		2.3	
SPACE			31		X				32		2.3	
SPACE			33			X			34	40/3	2.3	XCU-6
SPACE			35				X		36		2.3	
SPACE			37		X				38		2.3	
SPACE			39			X			40	40/3	2.3	XCU-7
SPACE			41				X		42		2.3	
CONNECTED KVA:	163.4				A	B	C				DESIGN DEMAND KVA:	120.9
CONNECTED HIGH PHASE AMPS:	470.0				55.3	56.4	51.7				DESIGN DEMAND AMPS:	335.8

PANEL NOTES:
A - PROVIDE CIRCUIT BREAKER WITH LOCK-ON DEVICE.
B - PROVIDE HACR CIRCUIT BREAKER.
C - EXISTING BREAKER TO REMAIN. NO NEW LOAD ON CIRCUIT.
BALANCE PHASE LOADS TO WITHIN 10% OF EACH OTHER.

EXISTING PANEL 'M-B'												
Location: Mezzanine		AIC: EXISTING										208/120 Volt, 3ø, 4w
Mounting: Surface												Main: MLO 400A
Circuit Description	KVA	CB	NO.	NOTE	A	B	C	NOTE	NO.	CB	KVA	Circuit Description
XBCU-1	4.1		1		X				2			SPARE
	4.1	45/3	3	C		X			4	20/3		
	4.1		5				X		6			
	4.1		7		X				8			
XBCU-2	4.1	45/3	9	C		X			10	20/3		SPARE
	4.1		11				X		12			
XBCU-3	2.9	30/3	13	C	X				14		2.0	XBCU-3
	2.9		15			X			16	30/3	2.0	
	2.9		17				X		18		2.0	
	4.1		19		X				20		1.0	
XBCU-4	4.1	45/3	21	C		X			22	20/3	1.0	SPARE
	4.1		23				X		24		1.0	
	2.9		25		X				26		2.0	
XBCU-5	2.9	30/3	27	C		X			28	30/3	2.0	XBCU-5
	2.9		29				X		30		2.0	
	2.9		31		X				32		2.0	
XBCU-6	2.9	30/3	33	C		X			34	30/3	2.0	XBCU-6
	2.9		35				X		36		2.0	
	2.9		37		X				38		2.0	
XBCU-7	2.9	30/3	39				X		40	30/3	2.0	XBCU-7
	2.9		41						42		2.0	
CONNECTED KVA:	98.7				A	B	C				DESIGN DEMAND KVA:	101.8
CONNECTED HIGH PHASE AMPS:	274.2				32.9	32.9	32.9				DESIGN DEMAND AMPS:	282.7

PANEL NOTES:
A - PROVIDE CIRCUIT BREAKER WITH LOCK-ON DEVICE.
B - PROVIDE HACR CIRCUIT BREAKER.
C - EXISTING BREAKER TO REMAIN. NO NEW LOAD ON CIRCUIT.
BALANCE PHASE LOADS TO WITHIN 10% OF EACH OTHER.

EXISTING PANEL 'P'												
Location: Mezzanine		22,000 AIC										208/120 Volt, 3ø, 4w
Mounting: Surface												Main: MCB 400A
Circuit Description	KVA	CB	NO.	NOTE	A	B	C	NOTE	NO.	CB	KVA	Circuit Description
DRINKING FOUNTAIN	0.5	20/1	1	D	X				2	20/1	0.8	RECEPTION RECEPTACLES
WAREHOUSE RECEPTACLES	0.2	20/1	3	D		X			4	20/1	0.7	PRINTER/ROUTER
CP-1	0.1	20/1	5	A			X	A	6	20/1	0.8	P.O.S. DED. RECS.
HVAC UNIT LIGHT/RECEPTACLES	0.4	20/1	7		X				8	20/1	0.8	P.O.S. DED. RECS.
BACK OF HOUSE CONV. RECEPTACLES	0.9	20/1	9			X		A	10	20/1	0.8	P.O.S. DED. RECS.
SPARE			11				X	A	12	20/1	0.8	P.O.S. DED. RECS.
TOILET RECEPTACLES/EF-1	0.4	20/1	13	D	X				14	20/1	1.5	P.O.S. GENERAL RECS.
CORRIDOR RECEPTACLES	1.1	20/1	15	D		X			16	20/1	0.5	DISPLAY CASE LIGHTING
EXISTING HANDICAP DOOR ACTUATOR	1.0	20/1	17	D			X	A	18	20/1	1.0	ATM MACHINES
HAND DRYER	0.6	20/1	19	C	X			A	20	20/1	1.2	INTERIOR SIGNS
HAND DRYER	0.6	20/1	21	C		X		A	22	20/1	0.5	TV RECEPTACLES
RESTROOM RECEPTACLES	0.4	20/1	23				X	A	24	20/1	0.5	WALL CASEWORK DISPLAY LIGHTS
MEZZANINE MECH RECEPTACLES	0.8	20/1	25	D	X				26	20/1	0.4	RETAIL AREA RECEPTACLES
REFRIGERATOR	1.0	20/1	27	C			X		28	20/1	1.0	FULFILLMENT AREA PLUGMOLD
MICROWAVE	1.0	20/1	29				X		30	20/1		SPARE
APPLIANCE RECEPTACLE	0.5	20/1	31		X				32	20/1	1.0	FULFILLMENT AREA PLUGMOLD
OFFICE RECEPTACLES	1.3	20/1	33	D		X			34	20/1	1.0	FULFILLMENT AREA PLUGMOLD
WORK AREA PLUGMOLD	0.5	20/1	35				X	A	36	20/1	1.0	SAFE POWER
WORK AREA PLUGMOLD	0.5	20/1	37		X				38	20/1	0.2	VAULT P.O.S. DED. REC.
WORK AREA PLUGMOLD	0.5	20/1	39			X			40	20/1	0.2	VAULT P.O.S. DED. REC.
SPARE			41				X		42	20/1	0.2	VAULT P.O.S. DED. REC.
CONNECTED KVA:	57.4				A	B	C				DESIGN DEMAND KVA:	64.2
CONNECTED HIGH PHASE AMPS:	186.7				22.4	19.1	15.9				DESIGN DEMAND AMPS:	178.2

PANEL NOTES:
A - PROVIDE CIRCUIT BREAKER WITH LOCK-ON DEVICE.
B - PROVIDE HACR CIRCUIT BREAKER.
C - BREAKER SHALL BE 5 Ma 'G.F.I.' TYPE
D - EXISTING BREAKER TO REMAIN. NO NEW LOAD ON CIRCUIT.
BALANCE PHASE LOADS TO WITHIN 10% OF EACH OTHER.

LOAD SUMMARY - PANEL 'M-A'			
	CONNECTED KVA	DESIGN FACTOR	DESIGN DEMAND KVA
LIGHTING	0.0	1.25	0.0
RECEPTACLES	0.0	1.0	0.0
SIGN	0.0	1.25	0.0
WATER HEATER	22.2	1.0	22.2
HVAC (LARGEST)	0.0	1.25	0.0
HVAC (REMAINING)	98.7	1.0	98.7
HVAC (NONCOINCIDENTAL)	42.5	0.0	0.0
MISCELLANEOUS	0.0	1.0	0.0
TOTAL KVA:	163.4		120.9
TOTAL AMPS:	453.9		335.8

LOAD SUMMARY - PANEL 'M-B'			
	CONNECTED KVA	DESIGN FACTOR	DESIGN DEMAND KVA
LIGHTING	0.0	1.25	0.0
RECEPTACLES	0.0	1.0	0.0
SIGN	0.0	1.25	0.0
WATER HEATER	0.0	1.0	0.0
HVAC (LARGEST)	12.3	1.25	15.4
HVAC (REMAINING)	86.4	1.0	86.4
HVAC (NONCOINCIDENTAL)	0.0	0.0	0.0
MISCELLANEOUS	0.0	1.0	0.0
TOTAL KVA:	98.7		101.8
TOTAL AMPS:	274.2		282.7

LOAD SUMMARY - PANEL 'P'			
	CONNECTED KVA	DESIGN FACTOR	DESIGN DEMAND KVA
LIGHTING	22.2	1.25	27.8
RECEPTACLES	8.9	1.0	8.9
SIGN	4.8	1.25	6.0
WATER HEATER	0.0	1.0	0.0
HVAC (LARGEST)	0.0	1.25	0.0
HVAC (REMAINING)	0.1	1.0	0.1
HVAC (NONCOINCIDENTAL)	0.0	0.0	0.0
MISCELLANEOUS	21.4	1.0	21.4
TOTAL KVA:	57.4		64.2
TOTAL AMPS:	159.4		178.2


LOAD SUMMARY - PANEL 'L'			
	CONNECTED KVA	DESIGN FACTOR	DESIGN DEMAND KVA
LIGHTING	21.2	1.25	26.5
RECEPTACLES	0.6	1.0	0.6
SIGN	3.6	1.25	4.5
WATER HEATER	0.0	1.0	0.0
HVAC (LARGEST)	0.0	1.25	0.0
HVAC (REMAINING)	0.0	1.0	0.0
HVAC (NONCOINCIDENTAL)	0.0	0.0	0.0
MISCELLANEOUS	4.8	1.0	4.8
TOTAL KVA:	30.2		36.4
TOTAL AMPS:	83.9		101.1

EXISTING - - - - -
NEW - - - - -

POWER RISER DIAGRAM NOTES

- EXISTING PAD MOUNTED UTILITY TRANSFORMER TO REMAIN. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID.
- EXISTING CONDUIT(S) AND 800 AMP FEEDER WIRE. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID.
- EXISTING 800A/3P, NEMA 3R, FUSED DISCONNECT SWITCH WITH (3) 800A FUSES. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID.
- EXISTING 3-1/2" C.-4#500 KCMIL CU, + 1#3 GND. TO REMAIN. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID.
- EXISTING 120/208V, 3PH, 4W PANELS 'M-A', 'M-B', 'P' AND 'L' TO REMAIN. REFER TO PANEL SCHEDULES ON THIS SHEET FOR ADDITIONAL INFORMATION.

NOTE:
ELECTRICAL SYSTEM SHALL BE GROUNDED AND BONDED PER NEC REQUIREMENTS AND AUTHORITY HAVING JURISDICTION.



1 POWER RISER DIAGRAM NOTES

EXISTING PANEL 'L'												
Location: Mezzanine		22,000 AIC										208/120 Volt, 3ø, 4w
Mounting: Surface												Main: MLO 400A
Circuit Description	KVA	CB	NO.	NOTE	A	B	C	NOTE	NO.	CB	KVA	Circuit Description
MEZZANINE/MECH LIGHTS	1.2	20/1	1	D	X				2	20/2	1.0	FLAG/FACADE LTG. (VIA CONTACTOR)
WAREHOUSE LIGHTS	1.1	20/1	3	D		X			4		1.0	
NON-CANNABIS STORAGE LIGHTS	1.5	20/1	5	D			X		6	20/2	1.0	PARKING LOT LTG. (VIA CONTACTOR)
STOREFRONT SIGN	1.2	20/1	7	A	X				8		1.0	
SPARE			9				X		10	20/1	1.2	SIGNAGE